




WICHITA STATE UNIVERSITY

Discontinuous Fiber Thermoplastic Composite Qualification Framework Development

John Tomblin
Rachael Andrulonis
Royal Lovingfoss
Brandon Saathoff
Tomas Lorik

May 22, 2024



Joint Centers of Excellence for Advanced Materials



Federal Aviation
Administration



NIAR

- John Tomblin, PhD
- Rachael Andrulonis
- Royal Lovingfoss
- Brandon Saathoff
- Tomas Lorik



FAA

- Larry Ilcewicz, PhD
- Cindy Ashforth
- Ahmet Oztekin, PhD
- Dave Stanley (Technical Monitor)




Sekisui Aerospace

- Scott James
- Daniel Miranda




Research Partners:



DFC Background and Research Motivation

- **Thermoplastic composites** are an attractive material solution for accelerating the manufacturing production rate of aerospace structural parts/components
- **Thermoset and thermoplastic** polymers have been used in discontinuous fiber composite applications. Thermoplastic polymers are the most attractive due to:
 - Reduction of manufacturing cycle time
 - Increased performance (fracture toughness, chemical resistance, etc.)

General DFC Compression Molding Process



Discontinuous Fiber (Molding Materials)	Continuous Fiber	Various Processing Methods
<p>Injection Molding Pellets</p> <p>Short Fiber Long Fiber</p>	<p>Fabric (Woven)</p>	
<p>Chopped Fiber Bulk Molding Compound (BMC - Series of Platelets)</p>	<p>Unidirectional Tape</p>	







Various Processing Methods

- Layup
 - Hand Layup
 - Automated Fiber Placement (AFP) / Automated Tape Layup (ATL)
- Consolidation/Molding/Forming
 - Press
 - Autoclave or Oven
- Hybrid/Other Processes
 - Continuous Compression Molding (CCM)
 - AFP In-Situ Consolidation (AFP-ISC)
 - Forming & Overmolding




*Each process described may or may not be relevant for each material type



Experimental Testing



Analysis Tool Development



*Platelet, Resin: 2D Shell, Interface: 3D Brick Cohesive Elements


Overall Goals

- Develop a **framework for the qualification** of new and innovative **thermoplastic** composite material systems including guidelines and recommendations for their characterization, testing, design, and utilization.
- Second goal: To transition the test data and guidelines generated in this program into shared databases, such as **CMH-17**.



Research Outputs

- **Trial tests** provide valuable lessons learned on temperature effects of key mechanical properties, test methods best suited for thermoplastic composites, and effects of key processing parameters
- **First public qualification of a continuous fiber thermoplastic composite** with material and process specifications
- Lessons learned, guidelines, and data made available to **CMH-17**
- **Qualification framework for chopped (discontinuous) fiber thermoplastic composites**




High Flow vs. Low Flow Panel Visual Comparison

Square Platelet – High Flow 13.5"x1.5" Panel




Square Platelet – Low Flow 12"x12" Panel




*panels not displayed to scale

Flow Platelet Size Thickness



Square Platelet – High Flow 7"x6.5" Panel




Square Platelet BMC
0.5" x 0.5"




Narrow Platelet BMC
0.5" x 0.0625"



High Flow Panel Size Description - 13" x 1.5"





High Flow Panel Size Description - 7.0"x6.5"



Non-Destructive Inspection Techniques

Through-Transmission Ultrasonic Inspections




X-Ray Computed Tomography Inspection




Summary of TTU C-Scan Results

Low Flow 12.0" x 12.0" Panel (Thickness: 0.15")

Square Platelet: 8-1-3 -5.9dB



Narrow Platelet: 7-2-1 -5.9dB



High Flow 12.5" x 1.5" Panel (Thickness: 0.15")

Square Platelet

3-3-1-1 -5.9dB



3-3-1-1 7dB



Narrow Platelet

4-19-1-2 -5.9dB




4-19-1-2 7dB




Low Flow 12.0" x 12.0" Panel (Thickness: 0.25")

Square Platelet: 6-1-1 -4.1dB




Narrow Platelet: 5-3-1 -4.1dB




High Flow 7.0" x 6.5" Panel (Thickness: 0.15")

Square Platelet: 4-6-2 -5.9dB




Narrow Platelet: 3-8-2 -5.9dB



Flow of Material
Entering Part Cavity
from Charge Cavity

Amplitude (%)



Square Platelet (0.5" x 0.5") – XRCT Process Comparisons


High Flow – 13.5" x 1.5" Panel (Thickness: 0.15")

Specimen ID: 4-9-1-OHT-RTA-1

Flow Direction

Specimen ID: 4-9-1-OHT-RTA-2


Flow Direction



High Flow – 7" x 6.5" Panel (Thickness: 0.15")

Specimen ID: 4-10-1-OHT-RTA-1


Specimen ID: 4-10-1-OHT-RTA-2



Low Flow – 12" x 12" Panel (Thickness: 0.15")

Specimen ID: 8-7-1-OHT-RTA-1




Specimen ID: 8-7-1-OHT-RTA-2



Square Platelet Panel Fiber Volume & Void Content

Fiber & Void Content

- ≈1" x 0.5" samples (target≈1.5-grams) extracted from each panel (locations documented for each panel)
 - ASTM D792-13 "Standard Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement"
 - ASTM D3171-15 "Standard Test Methods for Constituent Content of Composite Materials" (Method I, Procedure B)
 - ASTM D2734-16 "Standard Test Methods for Void Content of Reinforced Plastics"
- Density:
 - Resin: 1.31 g/cc (%crystalline=30%)
 - Fiber: 1.79 g/cc





Narrow Platelet Panel Fiber Volume & Void Content

Fiber & Void Content

- $\approx 1'' \times 0.5''$ samples (*target ≈ 1.5 -grams*) extracted from each panel (locations documented for each panel)
 - ASTM D792-13 "Standard Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement"
 - ASTM D3171-15 "Standard Test Methods for Constituent Content of Composite Materials" (Method I, Procedure B)
 - ASTM D2734-16 "Standard Test Methods for Void Content of Reinforced Plastics"
- Density:
 - Resin: 1.31 g/cc (%crystalline=30%)
 - Fiber: 1.79 g/cc

Square and Narrow Platelet Comparisons

Platelet	Flow	Property	Average	Specimen Qty
Square (0.5" x 0.5")	High	Fiber Volume [%]	56.863	123
		Void Content Volume [%]	2.249	
	Low	Fiber Volume [%]	57.216	28
		Void Content Volume [%]	1.378	
Narrow (0.5" x 0.0625")	High	Fiber Volume [%]	56.175	44
		Void Content Volume [%]	2.294	
	Low	Fiber Volume [%]	58.097	11
		Void Content Volume [%]	1.575	



Mechanical Test Matrix

Square Platelets (0.5" x 0.5")													
Flow	Thickness (in.)	Test Type	Flow Direction	Panel Size (in.)	Geometry (in.)	ASTM Method Description	CTA -65F	RTA	ETA1 180F	ETW1 180F	ETA2 350F	ETW2 350F	
High	0.15"	UNT	Long.	13.5" x 1.5"	12.0" x 1.5"	D3039	6	6	6	6	6	6	
		UNT	Trans.	7.0" x 6.5"	7.0" x 1.5"	D3039	6	6	6	6	6	6	
		UNC	Long.	13.5" x 1.5"	12.0" x 1.5"	D8066	6	6	6	6	6	6	
		UNC	Trans.	7.0" x 6.5"	7.0" x 1.5"	D8066	6	6	6	6	6	6	
		V-Notched Rail Shear	Long.	13.5" x 1.5"	3.0" x 1.5"	D7078		6					
		V-Notched Rail Shear	Trans.	7.0" x 6.5"	3.0" x 2.2"	D7078		6					
		Flexural (3-Pt Bend)	Long.	13.5" x 1.5"	5.5" x 0.5"	D790, 3 pt bend		6					
		Flexural (3-Pt Bend)	Trans.	7.0" x 6.5"	5.5" x 0.5"	D790, 3 pt bend		6					
		OHT	Long.	13.5" x 1.5"	12.0" x 1.5"	D5766, Ø:0.25"		6					
		OHT	Trans.	7.0" x 6.5"	7.0" x 1.5"	D5766, Ø:0.25"		6					
	OHT	Long.	7.0" x 6.5"	7.0" x 4.5"	D5766, Ø:0.75"		6						
	OHT	Trans.	7.0" x 6.5"	7.0" x 4.5"	D5766, Ø:0.75"		6						
	OHT	Long.	7.0" x 6.5"	7.0" x 6.0"	D5766, Ø:1.0"		6						
	OHT	Trans.	7.0" x 6.5"	7.0" x 6.0"	D5766, Ø:1.0"		6						
	OHC	Long.	13.5" x 1.5"	12.0" x 1.5"	D6484, Ø:0.25"		6						
	OHC	Trans.	7.0" x 6.5"	7.0" x 1.5"	D6484, Ø:0.25"		6						
	SSB	Long.	13.5" x 1.5"	5.5" x 1.5"	D596C, Ø:0.25"		6						
	SSB	Trans.	7.0" x 6.5"	5.5" x 1.5"	D5961,C, Ø:0.25"		6						
	CAI	Long.	7.0" x 6.5"	6.0" x 4.0"	D7136/D7137		6						
	CAI	Trans.	7.0" x 6.5"	6.0" x 4.0"	D7136/D7137		6						
Low	0.25"	UNT	N/A	12.0" x 12.0"	12.0" x 1.5"	D3039		6	6		6		
		UNC		12.0" x 12.0"	12.0" x 1.5"	D8066		6					
		V-Notched Rail Shear		12.0" x 12.0"	3.0" x 2.2"	D7078		6					
		OHT		12.0" x 12.0"	12.0" x 1.5"	D5766, Ø:0.25"		6					
	0.15"	UNT	N/A	12.0" x 12.0"	12.0" x 1.5"	D3039	6	6	6	6	6	6	
		UNC		12.0" x 12.0"	12.0" x 1.5"	D8066	6	6	6	6	6	6	
		V-Notched Rail Shear		12.0" x 12.0"	3.0" x 2.2"	D7078		6					
		Flexural (3-Pt Bend)		12.0" x 12.0"	5.5" x 0.5"	D790		6					
		OHT		12.0" x 12.0"	12.0" x 1.5"	D5766, Ø:0.25"		6					
		OHT		12.0" x 12.0"	12.0" x 4.5"	D5766, Ø:0.75"		6					
		OHT		12.0" x 12.0"	12.0" x 6"	D5766, Ø:1.0"		6					
		OHC		12.0" x 12.0"	12.0" x 1.5"	D6484, Ø:0.25"		6					
		SSB		12.0" x 12.0"	5.5" x 4.0"	D5961,C, Ø:0.25"		6					
		CAI		12.0" x 12.0"	6.0" x 1.5"	D7136/D7137		6					



Narrow Platelets (0.5" x 0.0625")															
Flow	Thickness (in.)	Test Type	Flow Direction	Panel Size (in.)	Geometry (in.)	ASTM Method Description	CTA -65F	RTA	ETA1 180F	ETW1 180F	ETA2 350F	ETW2 350F			
High	0.15"	UNT	Long.	13.5" x 1.5"	12.0" x 1.5"	D3039		6	6		6				
		UNT	Trans.	7.0" x 6.5"	7.0" x 1.5"	D3039		6	6		6				
		UNC	Long.	13.5" x 1.5"	12.0" x 1.5"	D8066		6							
		UNC	Trans.	7.0" x 6.5"	7.0" x 1.5"	D8066		6							
		V-Notched Rail Shear	Long.	13.5" x 1.5"	3.0" x 1.5"	D7078		6							
		V-Notched Rail Shear	Trans.	7.0" x 6.5"	3.0" x 2.2"	D7078		6							
		Open Hole Tension	Long.	13.5" x 1.5"	13.0" x 1.5"	D5766, Ø:0.25"		6							
		Open Hole Tension	Trans.	7.0" x 6.5"	7.0" x 1.5"	D5766, Ø:0.25"		6							
		Low	0.25"	UNT	N/A	12.0" x 12.0"	12.0" x 1.5"	D3039		6	6		6		
				UNC		12.0" x 12.0"	12.0" x 1.5"	D8066		6					
V-Notched Rail Shear	12.0" x 12.0"			3.0" x 2.2"		D7078		6							
OHT	12.0" x 12.0"			12.0" x 1.5"		D5766, Ø:0.25"		6							
OHT	12.0" x 12.0"			12.0" x 1.5"		D3039		6	6		6				
0.15"	UNC		12.0" x 12.0"	12.0" x 1.5"		D8066		6							
	V-Notched Rail Shear		12.0" x 12.0"	3.0" x 2.2"		D7078		6							
	OHT		12.0" x 12.0"	12.0" x 1.5"		D5766, Ø:0.25"		6							
	OHT		12.0" x 12.0"	12.0" x 1.5"		D3039		6	6		6				
	OHT		12.0" x 12.0"	3.0" x 2.2"		D7078		6							

**Total: 396
Square Platelet
Specimens**

**Total: 144 Narrow Platelet
Specimens**

Square & Narrow Platelet Tension Comparison




- In the majority of alike configurations, the narrow platelet material resulted in higher strengths and moduli in comparison to the square platelet material
 - High Flow (Long. To Flow) high C.V. and lower average strength
 - Significant difference in strength witnessed for low flow configurations
- High variability witnessed for ETA 350°F & ETW 350°F condition (strength and modulus)
- Similar strength and modulus witnessed for 0.25" & 0.15" thick specimens



**CTD (-65°F) / ETA (180°F)
Test Setup (Bi-Axial Ext)**

**RTA
Test Setup (DIC)**




**ETA/ETW (350°F)
Test Setup (Uni-Axial Ext 2" GL)**



2" gage length used to encompass more platelets



Square & Narrow Platelet Open Hole Tension (OHT) Comparison

- The propensity for failure away from the hole was high in the $\varnothing 0.25''$ hole.
 - Notched strength was similar to un-notched strength
- $\varnothing 0.75''$ & $\varnothing 1.0''$ specimen configurations had 100% failure through the hole.
 - Specimens with $\varnothing 0.75''$ experienced a knock down of approx. 20% (longitudinal 40%)
 - Specimens with $\varnothing 1.0''$ experienced a knock down of approx. 30% (longitudinal 60%)




Square & Narrow Platelet Compression Comparison

- The square and narrow platelet specimens performed similarly in respective configurations
 - High Flow Square Platelet (Transverse To Flow) lower strength than expected
 - Similar strengths witnessed between both flow conditions
- Additional specimen batch used to compare compressive properties between different panel sizes



High & Low Flow Compression After Impact (CAI) Comparison

- All three configurations experienced varying sensitivity to the damage size.
 - Low flow specimens had the highest sensitivity to damage size.
 - Transverse to flow had the lowest sensitivity to damage size.
- All three configurations experienced knockdowns ranging from 15%-45%




Low Flow

Impact Energy: 208.55 in-lb




High Flow (Long.)


Impact Energy: 193.36 in-lb



CAI Strength Comparison




CAI Strength vs Damage Area Comparison




Square & Narrow Platelet V-Notch Rail Shear Comparison


- Specimens with similar manufacturing conditions experienced similar strength and modulus
 - Averages for low flow specimens of both thicknesses were within 5% of respective platelet type
- Knockdown for modified geometry is believed to be due to both the geometry and the flow characteristics
- The majority of low flow specimens did not reach the 0.2% offset strength



Shear Strength Comparison





Shear Modulus Comparison



Square Platelet Single Shear Bearing (SSB) Comparison

- Each configuration of specimen had a different predominate failure mode.

- High Flow (Long.): Mixed Mode Bearing/Cleavage
- High Flow (Trans.): Net Tension
- Low Flow: Bearing



Qualification Framework for DFCs

Qualification Downselect

- **Low Flow** Process
- Narrow Platelet: **0.0625"x0.5"**
- **12" x 12"** Panel size
- Panel Thickness: **0.15"**
- Modified Geometry:
 - **Tension**
 - **Compression**
 - **In-Plane Shear**
 - **Flexure**
 - **Bearing**
 - **Tension After Impact**
- OHT specimen configuration with **Ø0.75"** hole.

Material Specs

- Base Spec NMS 145: **Solvay APC [PEKK/AS4D] 12K**
- NMS 145/1: **Wide Format Prepreg (12" width)**
- NMS 145/2: **Bulk Molding Compound (.065" x 0.5")**
- **NPS 81450:** Fabrication of NMS 145 Qualification, Equivalency, and Acceptance Test Panels



Test Plan


- **NTP 1450Q1**
- **Per Environmental Condition:**
 - 3 Material Batches
 - 3 panels per batch
 - 3 specimens per panel
- Use of Extensometers
- Mechanical Testing at **CTA, RTA, 300 °F, 250°F, and 180°F**
- Fluid sensitivity screening using ASTM D3039 Tension
- Total of 219 panels required

Material Batch

Panel Manufacturing Process

Number of Specimens Required per Test Method & Environment

PER ENVIRONMENT CONDITION AND TEST METHOD



Qualification Mechanical Test Matrix

Test Type Abbreviation	Test Type Description	Test Specimen Geometry Length x Width x Thickness [in]	Property	Number of Batches x Number of Panels x Number of Test Specimens					
				Test Temperature/Moisture Condition					
				CTA	RTA	ETA1	ETW1	ETA2	ETA3
UNT	ASTM D3039 Un-notched Tension (1)	12 x 1.5 x 0.15	Strength and Modulus	3x3x3	3x3x3	3x3x3	1x3x3	1x3x3	1x3x3
UNC	ASTM D8066 Un-notched Compression (1)(2)	12 x 1.5 x 0.15	Strength and Modulus	1x3x3	3x3x3	3x3x3	1x3x3	1x3x3	1x3x3
IPS	ASTM D7078 V-Notch Shear (1)	3 x 2.2 x 0.15	Strength & Modulus	3x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
FLX	ASTM D790 Flexure	5.5 x 1.5 x 0.15	Strength and Modulus	3x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
OHT	ASTM D 5766 Open Hole Tension (1)(3)	12 x 4.5 x 0.15 (0.75 dia. Hole)	Strength	3x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
OHC	ASTM D6484 Open Hole Compression (1)	12 x 1.5 x 0.15 (0.25 dia. Hole)	Strength	1x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
SSB	ASTM D5961 Single Shear Bearing	5.5 x 1.5 x 0.15 (0.25 dia. Hole, e/D=3)	Strength & Deformation	1x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
CAI	ASTM D7136 & D7137 Compression After Impact (1500 in.lb/in)	6 x 4 x 0.15	Strength	1x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A
TAI	ASTM D7136 & D5766 Tension After Impact (1500 in.lb/in)	12 x 4.5 x 0.15	Strength	1x3x3	3x3x3	3x3x3	1x3x3	N/A	N/A

Note 1: Coupon sized considering the bulk molding compound platelet width and length.

Note 2: UNC specimens tested using OHC compression fixture to stabilize specimen.

Note 3: Hole size modified for bulk molding compound platelet fiber length.

Note 4: ETA1/ETW1 is @ 180°F, ETA2 is @ 250 °F, & ETA3 is @ 300 °F

- **Pre-Qualification Trial Testing**
 - Completed trial test matrices to evaluate three key process parameters.
- **Qualification**
 - Currently have all NCAMP documents drafted and shared with material suppliers.
- **Benefit to Aviation**
 - Publicly available DFC data linked to M&P Specifications.
 - Lessons learned, guidelines for characterization, and data made available to **CMH-17**.

Thank you


NIAR

WICHITA STATE UNIVERSITY

Questions?



Square Platelet Open Hole Compression (OHC) Comparison

- Adequate failure modes through the hole were witnessed for all specimens except for one.
 - High Flow (long): Multi-mode failure above the hole.
- All specimen configurations experienced an approx. 10% knock down to strength



>> **12.0-in length** used for 13.5-in x 1.5-in High Flow panels & Low Flow 12.0-in x 12.0-in panels
 *2 in. Extensometer used

>> **7.0-in length** used for 7.0-in x 6.5-in High Flow Panels
 *2 in. Extensometer used



ASTM D7028 – “Standard Test Method for Glass Transition Temperature (DMA Tg) of Polymer Matrix Composites by Dynamic Mechanical Analysis (DMA)”

Platelets	Flow	Thick-ness	Panel Size	Sample ID	Onset Storage Modulus Tg [°F]	Peak of Tangent Delta Tg [°F]	
Square 0.5" x 0.5"	High	0.15"	13" x 1.5"	4-1-1	289.11	331.86	
				4-1-2	290.21	332.22	
				4-1-3	288.72	330.94	
			7" x 6.5"	8-13-1	286.52	331.70	
				8-13-2	278.98	326.79	
				8-13-3	284.65	331.93	
	Low	0.25"	12" x 12"	6-1-1	289.35	333.43	
				8-1-1	288.57	332.62	
				8-1-2	289.67	333.68	
		0.15"		8-1-3	286.93	331.74	
				13" x 1.5"	3-5-1	278.47	326.17
				7" x 6.5"	3-6-2	283.73	325.54
Low	0.15"	12" x 12"	7-3-1	282.27	324.36		

Average [°F] **285.94** **330.23**
 Standard Deviation 4.02 3.25
 C.V. [%] 1.41% 0.99%

ASTM D3418 – “Standard Test Method for Transition Temperatures and Enthalpies of Fusion and Crystallization of Polymers by Differential Scanning Calorimetry”

Platelets	Flow	Thick-ness	Panel Size	Sample ID	Melting Peak Temperature [°F]	Enthalpy of Melting ΔHm [J/g]	Crystallization Peak Temperature [°F]	Enthalpy of Crystallization ΔHc [J/g]	Degree of Crystallinity [%]			
Square 0.5" x 0.5"	High	0.15"	13" x 1.5"	4-1-1	648.64	9.686	559.17	12.794	21.91			
				4-1-2	645.04	8.557	560.48	12.095	19.36			
				4-1-3	646.27	11.297	559.71	11.368	25.56			
			7" x 6.5"	8-13-1	644.74	11.794	550.72	12.331	26.68			
				8-13-2	651.54	13.586	550.24	12.766	30.74			
				8-13-3	650.14	12.194	552.83	12.962	27.59			
	Low	0.25"	12" x 12"	6-1-1	649.51	10.873	552.40	13.528	24.60			
				8-1-1	650.86	13.159	553.95	13.856	29.77			
				8-1-2	651.20	12.577	553.89	12.997	28.45			
		0.15"		8-1-3	650.26	12.897	553.66	13.259	29.18			
				High	0.15"	13" x 1.5"	3-5-1	643.59	11.228	562.33	13.441	25.40
							3-5-2	648.07	11.732	562.59	13.235	26.54
							3-5-3	651.02	10.345	561.83	14.720	23.40
				Low	0.15"	7" x 6.5"	3-6-1	651.76	13.873	565.38	14.707	31.39
							3-6-2	653.29	13.032	565.32	13.435	29.48
3-6-3	653.00	14.560	565.63				15.142	32.94				
12" x 12"	7-3-1	650.86	13.159		553.95	13.858	29.77					
	7-3-2	651.20	12.577		553.89	12.997	28.45					
	7-3-3	650.26	12.897		553.66	13.259	29.18					

Average [%] **27.39**
 Standard Deviation 3.41
 C.V. [%] 12.45%