



\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**B0001852**

***ADDENDUM # 1***

**FROM:** *Robby Murray*

Campus Box 38

Ph: 316-978-5185

Fax: 316-978-3528

**TO:** Interested Bidders,

**DATE:** June 8<sup>th</sup>, 2024

**SUBJECT:** Addendum #1

**CLARIFICATIONS TO THE BID SPECIFICATIONS:**

**Question #1:** I went through the bid and see where it stated the pressure requirement, but I don't see what the estimated monthly volume is projected to be. That would help me understand what size tank would need to be used for your application.

**Question #2:** I was reading through your bid and it does not have a particular volume of argon on it to properly size the bulk tank.

**Answer #1 and #2:**

We will go through roughly 300 gallons per day on average, so if you multiply that out over a month that is 9,000 gallons, so I would think a 4,500-gallon tank and you fill it twice per month or so.

**The questions contained herein and the answers associated with these questions shall become part of the scope of work of this Request for Proposal.**

**NO. OF PAGES (including cover sheet): 1**

**Bid Responses must be submitted to WSU Office of Purchasing prior to the bid closing date and time in the format as described in the original bid solicitation!**

**Wichita State University**  
**Office of Purchasing**  
Robby Murray  
1845 Fairmount, Campus Box 38  
Jardine Hall Rm. 201  
Wichita, KS 67260-0038  
Phone: 316-978-5185  
Fax: 316-978-3107